Change Log

Form:Change Log:11-26

ALTRONIC



All rights reserved © ALTRONIC, LLC 2026

All rights reserved © ALTRONIC, LLC 2026

Table of Contents

Change Log 1

All rights reserved © ALTRONIC, LLC 2026

All rights reserved © ALTRONIC, LLC 2026

Change Log

Release Version	Section	Description
2.1	Channels	Low set points should be before high set points (Safety and Control)
2.1	Dashboard	Need a way to create virtual buttons (On/Off, Manual/Auto)
2.1	Dashboard	Long labels do not contain themselves to the component bounds and automatically resize. Example, LED box, a long label will go on top the box and overwrite other components.
2.1	Dashboard	Long labels do not contain themselves to the component bounds and automatically resize. Example, LED box, a long label will go on top the box and overwrite other components.
2.1	Comms	Modbus registers are all read only, where are all the settings for setpoints and such? WE NEED THIS AS A STANDARD for all control panels. Everything should be configurable via modbus.
2.1	HMI	Must have a refresh button on the Dashboard and values page so it will reload the channel labels. Currently you must reboot each time to force a reload.
2.1	Dashboard	Need to be able to Insert a new HMI page between two existing pages.
2.1	Dashbaord	Sometimes clicking on the delete (trashcan) brings up the channel selector and adds a component instead of just removing the component.
2.1	Dashbaord	Need ability to set background color of Virtual Channels to show alarm state, faults,etc

From:
https://staging.altronic.a2hosted.com/ - **wiki STAGING !!!!!**

Permanent link:
https://staging.altronic.a2hosted.com/doku.php?id=documents:de4000:de4000changelog&rev=1643051029

Last update: **2022/01/28 21:17**

All rights reserved © ALTRONIC, LLC 2026